



## Recommendation for Action

**File #:** 21-2396, **Agenda Item #:** 61.

8/26/2021

### Posting Language

Set a public hearing to consider an ordinance regarding floodplain variances for the construction of an office building and associated parking at 1514 W. Koenig Lane within the 25-year and 100-year floodplains of the Hancock Branch Tributary of Shoal Creek. (Suggested date September 30, 2021, at Austin City Hall, 301 West Second Street, Austin, TX).

### Lead Department

Watershed Protection Department.

### Fiscal Note

A fiscal note is not required.

### For More Information:

Kevin Shunk, 974-9176; Karl McArthur, 974-9126.

### Council Committee, Boards and Commission Action:

December 2, 2020 - Environmental Commission recommended denial of a variance to City Code Section 25-8-261 (Critical Water Quality Zone Development) to construct in the Critical Water Quality Zone with a 9-0 vote with Commissioners Creel and Nill absent.

January 12, 2021 - Planning Commission approved the variance to City Code Section 25-8-261 (Critical Water Quality Zone Development) on an 11-0 vote with Commissioner Seeger abstaining and one vacancy on the Commission.

### Additional Backup Information:

Joel Levine, owner of 1514 W. Koenig, through his engineer, Katie Kam of Wheels & Water, LLC, seeks to obtain a site development permit for a proposed 3-story office building located at 1514 W. Koenig Lane. The property to be redeveloped consists of one lot totaling 0.17 acres and contains one approximately 900 square-foot residential building and one detached garage. The entirety of the property is located within the 25-year and 100-year floodplains of the Hancock Branch Tributary of Shoal Creek. As part of the site's redevelopment, the applicant proposes to demolish the existing buildings and construct a three-story commercial building totaling 4,125 square feet of conditioned area (1st floor parking and office use, 2 floors of office use above). The proposed building will encroach into the 100-year floodplain as well as the 25-year floodplain. The site plan application associated with the project is SP-2019-0027CT.

The owner seeks variances to the City of Austin's floodplain management regulations to: 1) encroach on the 25- and 100-year floodplains with the proposed building; 2) not provide normal access from the building to an area that is a minimum of one-foot above the design flood elevation (100-year floodplain); and 3) alter the property in a way that increases its nonconformity.

The proposed building will have approximately 11% of its conditioned space a minimum of 2 feet above the 100-year floodplain. The remaining portions of the building's conditioned space will be more than 14 feet

---

above the 100-year floodplain. The elevation of the proposed parking area will be a minimum of 2 feet above the 100-year floodplain.

However, the proposed development does not satisfy the code provisions for means of egress or safe access, which requires that normal access from the building to the right-of-way be along an access path that is at least one-foot above the 100-year floodplain elevation.

**Strategic Outcome(s):**

Safety.